


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 1/05/2025

It is certified that an inspection team headed by K.N. Sharma (Assistant Engineer) (Name of Officers with designation) from Bhind. PHED inspected the **CITY CENTRAL SCHOOL DAK BUNGLOW ATER ROAD BHIND** (Name & Address of the school) on 1/05/2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 1570 dated 1/05/2025 of 1/05/2026 (PHED Lab) certified that the **CITY CENTRAL SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year (1/05/2026)

Signature with Seal: 

Name

: K.N. Sharma

Designation

: Assistant EngineerName & Address of the Office / Department : P.H.E.DEtawa Road, Bhind.

To,

CITY CENTRAL SCHOOL

DAK BUNGLOW ATER ROAD BHIND

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Sharma
Principal
City Central School
Bhind (M.P.)

कार्यालय कार्यपालन यंत्री

लोक स्वास्थ्य यांत्रिकी विभाग खण्ड भिण्ड (मध्य प्रदेश)

क्रमांक 1570 /लैब /का०य०/लो०स्वा०या०/खण्ड/भिण्ड/25

दिनांक 02/05/2025

प्रति

City central school

Near Dak Bungalow Ater Road

Bhind (M.P)

विषय :- जल परीक्षण कर रिपोर्ट भेजने बावत ।

उपरोक्त विषयांतर्गत लेख है कि आपके द्वारा भेजे गये जल नमूने का जिला जल परीक्षण प्रयोगशाला में भौतिक रासायनिक एवं जैविक परीक्षण किया गया प्राप्त परीक्षण रिपोर्ट के आधार पर पानी पीने योग्य है संलग्न -परीक्षण रिपोर्ट।

कार्यपालन यंत्री


लोक स्वा स्थ्य यांत्रिकी


विभाग खंड भिण्ड

DISTRICT LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
SUB. DIVISION - BHIND (M.P.)

- | | |
|--------------------------|--|
| 1. Sample From | Durgesh Singh |
| 2. Particulars of Sample | City Central school Near Dak Bungalow Ater Road Bhind (M.P) |
| 3. Date of Collection | 01/05/2025 |
| 4. Date of Analysis | 02/05/2025 |

S. No.	Characteristics	Unit	As per BIS- 10500-2012 For Drinking Water		Result				
			Requirement Desirable Value	Permissible limit in the absence of Alternate Source					
PHYSICAL					Sample-1	Sample-2	Sample-3	Sample-4	Sample-5
1	Turbidity	NTU	1.0	5.0	0.0				
2	Colour	Cobalt	5	15	Nil				
3	Taste & Odour		Un Objectionable	Un Objectionable	Agreeble				
4	Temperature	C°	-	-	21.c				
CHEMICAL									
5	Ph Value	pH Scale	6.5 to 8.5	No Relaxation	6.5				
6	Alkalinity	Mg/L	200	600	10				
7	Chlorides (as Cl)	Mg/L	250	1000	7.9				
8	Nitrate as No 3	Mg/L	45	45	0.0				
9	Total hardness by standard E.D.T.A. Solution	Mg/L	200	600	12				
10	Calcium as Ca	Mg/L	75	200	2.4				
11	Magnesium as mg	Mg/L	30	100	1.4				
12	Iron	Mg/L	1.0	1.0	0.0				
13	Free Chlorine	Mg/L	0.2	1.0	Nil				
14	T.D.S.	Mg/L	500	2000	44				
15	Fluoride	Mg/L	1.0	1.5	0.0				
16	Arsenic	Mg/L	0.01	0.1	0.0				
17	Sulphate	Mg/L	200	400	...				
18	Bactological Feacul Coliform	Per 100 ml.	0	0	Nil				


Chemist
 Water Testing Lab
 P.H.E. Division - Bhind


Assistant Engineer
 Public Health Engineering
 Sub Division - Bhind (M.P.)